

## SPECIFICATIONS

# PXI-5404

100 MHz Bandwidth, 12-Bit PXI Waveform Generator

## Contents

---

Conditions.....	1
CH 0 Outputs.....	2
CH 0 SINE Out.....	2
CH 0 CLOCK Out.....	4
PFI 0 I/O.....	5
REF IN.....	6
REF OUT.....	7
Start Trigger.....	7
Sample Clock.....	8
Phase-Locked Loop (PLL) Reference.....	8
Internal Clock.....	8
External Calibration.....	9
Power.....	9
Environment.....	9
Physical.....	9
Compliance and Certifications.....	9
Safety.....	9
Electromagnetic Compatibility.....	10
CE Compliance.....	10
Online Product Certification.....	10
Environmental Management.....	10

## Conditions

---

Specifications are valid under the following conditions unless otherwise noted:

- Ambient temperature range of 0 °C to 50 °C
- Output voltage amplitudes with a 50 Ω load
- SINE out voltage amplitude of 2 Vpk-pk with a 50 Ω load
- CLOCK out level of 5 V
- External calibration performed between 18 °C and 28 °C

Typical specifications were determined on a small sampling of PXI-5404 waveform generators.

# CH 0 Outputs

Both CH 0 outputs generate the same frequency simultaneously.

Number of outputs	1 sine 1 clock
-------------------	-------------------

## CH 0 SINE Out

Connector type	SMB male
Frequency range	9 kHz to 105 MHz
Frequency resolution	1.07 $\mu$ Hz
Phase range	0° to 359.978°
Phase resolution	16,384 steps including endpoints ( $\sim 0.022^\circ$ )
Output impedance <sup>1</sup>	50 $\Omega$ , nominal
Output protection	10 V RMS
Sample rate	300 MS/s
Amplitude range	
Open load	4 V pk-pk to 2 V pk-pk
50 $\Omega$ load	2 V pk-pk to 1 V pk-pk
Amplitude resolution <sup>2</sup>	2,048 steps including endpoints
Amplitude accuracy (50 kHz)	$\pm 1\%$
Amplitude passband flatness (relative to the amplitude at 50 kHz) <sup>3</sup>	$\pm 0.2$ dB
Vertical resolution (open load)	
4 V pk-pk	12 bits
2 V pk-pk	11 bits
Bandwidth (0.2 dB) <sup>4</sup>	105 MHz
Filter	Analog, 7-pole elliptical

<sup>1</sup> VSWR 2:1. Spans 9 kHz to 105 MHz.

<sup>2</sup> Steps are  $\sim 977$   $\mu$ V with an open load and  $\sim 489$   $\mu$ V with a 50  $\Omega$  load.

<sup>3</sup> 9 kHz  $< f < 105$  MHz. At 15 °C to 50 °C.

<sup>4</sup> At 15 °C to 50 °C.

**Table 1.** Signal to Noise and Distortion (SINAD)<sup>5</sup>

Frequency	SINAD (dB), Typical
1 MHz	+51
10 MHz	+48
20 MHz	+45
50 MHz	+42
100 MHz	+42

**Table 2.** Spurious-Free Dynamic Range (SFDR) with Harmonics<sup>5</sup>

Frequency	SFDR with Harmonics (dBc), Typical
1 MHz	-55
10 MHz	-54
20 MHz	-49
50 MHz	-45
100 MHz	-53

**Table 3.** Total Harmonic Distortion (THD)<sup>6</sup>

Frequency	THD (dB), Typical
1 MHz	-50
10 MHz	-47
20 MHz	-40
50 MHz	-35
100 MHz	-30

Average noise density<sup>7</sup>0.126  $\mu\text{V RMS}/\sqrt{\text{Hz}}$   
-125 dBm/Hz<sup>5</sup> Amplitude set to 1.8 Vpk-pk (~ -1 dBFS). Spans 9 kHz to 150 MHz.<sup>6</sup> Amplitude set to 1.8 Vpk-pk (~ -1 dBFS). Includes the 2nd through the 6th harmonics.<sup>7</sup> Integrated from 9 kHz to 150 MHz.

# CH 0 CLOCK Out

Connector type	SMB male
Frequency range	DC to 105 MHz
Frequency resolution	1.07 $\mu$ Hz
Phase range	0° to 359.978°
Phase resolution	16,384 steps including endpoints (~ 0.022°)
Output impedance <sup>8</sup>	50 $\Omega$ , nominal
Output protection	+8 V to -4 V

**Table 4.** Output Current (Source or Sink)

Voltage Level	Current (mA), Typical
5.0 V	120
3.3 V	72
1.8 V	48

**Table 5.** Amplitude (Open Load)

Voltage Level	Amplitude (V)			
	VOL		VOH	
	Minimum	Maximum	Minimum	Maximum
5.0 V	-0.10	0.40	4.00	5.30
3.3 V			2.60	3.70
1.8 V			1.40	2.20

<sup>8</sup> VSWR 1.7:1. Spans DC to 105 MHz.

**Table 6.** Amplitude (50  $\Omega$  Load)<sup>9</sup>

Voltage Level	Amplitude (V)			
	VOL		VOH	
	Minimum	Maximum	Minimum	Maximum
5.0 V	-0.10	0.20	2.00	2.65
3.3 V			1.30	1.85
1.8 V			0.70	1.10

Rise/fall time (50  $\Omega$  load)

4 ns

Duty cycle range

25% to 75%

Duty cycle accuracy<sup>10</sup>

30% to 70%

 $\pm 2\%$ , typical

25% and 75%

 $\pm 4\%$ , typical

## PFI 0 I/O

Connector type

SMB male

Direction

Bidirectional

Frequency range

DC to 20 MHz

Input signal

Destinations

 PXI\_Trig <0..7> (backplane connector)  
 REF OUT (front panel connector)  
 Start Trigger

Input resistance

1 k $\Omega$   $\pm$  1%

Input protection

+8 V to -4 V

VIH

2.0 V

VIL

0.8 V

<sup>9</sup> If the CH 0 CLOCK out signal is terminated into a 50  $\Omega$  load, the voltage levels are divided by two.

<sup>10</sup> Spans 1.07  $\mu$ Hz to 60 MHz. SINE out at maximum amplitude.

## Output signal

Sources	PXI_CLK10 (backplane connector) Sample Timebase Clock (60 MHz) divided by $N$ ( $3 \leq N \leq 255$ ) REF IN (front panel connector) PXI_Trig <0..7> (backplane connector) PXI Star Trigger (backplane connector) CH 0 CLOCK out (front panel connector) Software Trigger Start Trigger
Output impedance <sup>11</sup>	50 $\Omega$ $\pm$ 5%
Output protection	+6 V to -1 V
Minimum VOH	
Open load	4.0 V
50 $\Omega$ load	2.0 V
Maximum VOL	
Open load	0.4 V
50 $\Omega$ load	0.2 V
Rise/fall time	4 ns

## REF IN

Connector type	SMB male
Frequency range	
Phase-Locked Loop (PLL) Reference destination	1 MHz to 20 MHz
All other destinations (besides PLL Reference)	200 kHz to 30 MHz
Destinations	PLL Reference REF OUT (front panel connector) PFI 0 (front panel connector) PXI_TRIG <0..7> (backplane connector)
Input impedance	1 k $\Omega$ $\pm$ 1%
Input protection (sine or square wave)	12 V pk-pk $\pm$ 5 V DC

<sup>11</sup> Spans DC to 20 MHz.

Amplitude (sine or square wave)	300 mV pk-pk to 5 V pk-pk
Input coupling	AC

## REF OUT

Connector type	SMB male
Frequency range	DC to 20 MHz
Sources	PXI_CLK10 (backplane connector) Sample Timebase Clock (60 MHz) divided by $N$ ( $3 \leq N \leq 255$ ) REF IN (front panel connector) PXI_Trig <0..7> (backplane connector) PXI Star Trigger (backplane connector) CH 0 CLOCK out (front panel connector) PFI 0 (front panel connector) Software Trigger Start Trigger
Output impedance <sup>12</sup>	50 $\Omega$ $\pm$ 5%
Output protection	+6 V to -1 V
VOH	
Open load	4.0 V
50 $\Omega$ load	2.0 V
VOL	
Open load	0.4 V
50 $\Omega$ load	0.2 V
Rise/fall time (50 $\Omega$ load)	4 ns

## Start Trigger

Sources	PFI 0 (front panel connector) PXI_Trig<0..7> (backplane connector) PXI Star Trigger (backplane connector) Software Immediate (Does not wait for a trigger.) <sup>13</sup>
Mode	Continuous

<sup>12</sup> Spans DC to 20 MHz.

<sup>13</sup> The default is Immediate.

Trigger detection	Edge (rising)
Minimum pulse width	10 ns
Trigger to SINE output delay	250 $\mu$ s, typical

## Sample Clock

Frequency	300 MS/s
Average phase noise density <sup>14</sup>	-112 dBc/Hz

## Phase-Locked Loop (PLL) Reference

Sources	PXI_CLK10 (backplane connector) REF IN (front panel connector) PXI_TRIG <0..7> (backplane connector) None (The PLL is not used.) <sup>15</sup>
Frequency accuracy	When using the PLL, the frequency accuracy of the PXI-5404 is solely dependent on the frequency accuracy of the PLL Reference source.
Lock time	200 ms, typical
Frequencies	3 MHz to 20 MHz in 1 MHz increments
Frequency locking range	$\pm$ 50 ppm
Duty cycle range	30% to 70%

## Internal Clock

Clock source	The clock circuitry of the PXI-5404 can either be locked to a reference signal using the PLL or use an onboard frequency reference, specifically the Internal Clock.
Frequency accuracy <sup>16</sup>	$\pm$ 25 ppm, maximum $\pm$ 11 ppm, typical
Frequency temperature coefficient	$\pm$ 0.4 ppm/ $^{\circ}$ C

<sup>14</sup> SINE out set to 10 MHz. Offset of 10 kHz  $\pm$  500 Hz. PLL Reference set to REF IN.

<sup>15</sup> The default is None. Refer to [Internal Clock](#) for more information.

<sup>16</sup> At 18  $^{\circ}$ C to 28  $^{\circ}$ C.



# External Calibration

---

Calibration interval	Specifications valid within one year of external calibration
Warm-up time	15 minutes

---

## Power<sup>17</sup>

---

+3.3 V rail	1 A
+5 V rail	550 mA
+12 V rail	180 mA
-12 V rail	50 mA

---

## Environment

---

Operating temperature	0 °C to 50 °C
Storage temperature	-20 °C to 70 °C

---

## Physical

---

Dimensions	3U, one-slot, PXI/cPCI module 21.6 cm × 2.0 cm × 13.0 cm (8.5 in. × 0.8 in. × 5.1 in.)
Weight	175 g (6.1 oz)

---

# Compliance and Certifications

---

## Safety

This product is designed to meet the requirements of the following electrical equipment safety standards for measurement, control, and laboratory use:

- IEC 61010-1, EN 61010-1
- UL 61010-1, CSA C22.2 No. 61010-1



**Note** For UL and other safety certifications, refer to the product label or the [Online Product Certification](#) section.

---

<sup>17</sup> With SINE out, CLOCK out, and REF OUT generating maximum amplitude waveforms into 50 Ω loads.

# Electromagnetic Compatibility

This product meets the requirements of the following EMC standards for electrical equipment for measurement, control, and laboratory use:

- EN 61326-1 (IEC 61326-1): Class A emissions; Basic immunity
- EN 55011 (CISPR 11): Group 1, Class A emissions
- AS/NZS CISPR 11: Group 1, Class A emissions
- FCC 47 CFR Part 15B: Class A emissions
- ICES-001: Class A emissions



**Note** In the United States (per FCC 47 CFR), Class A equipment is intended for use in commercial, light-industrial, and heavy-industrial locations. In Europe, Canada, Australia, and New Zealand (per CISPR 11), Class A equipment is intended for use only in heavy-industrial locations.



**Note** Group 1 equipment (per CISPR 11) is any industrial, scientific, or medical equipment that does not intentionally generate radio frequency energy for the treatment of material or inspection/analysis purposes.



**Note** For EMC declarations and certifications, refer to the [Online Product Certification](#) section.

## CE Compliance

This product meets the essential requirements of applicable European Directives, as follows:

- 2014/35/EU; Low-Voltage Directive (safety)
- 2014/30/EU; Electromagnetic Compatibility Directive (EMC)

## Online Product Certification

Refer to the product Declaration of Conformity (DoC) for additional regulatory compliance information. To obtain product certifications and the DoC for this product, visit [ni.com/certification](#), search by model number or product line, and click the appropriate link in the Certification column.

## Environmental Management

NI is committed to designing and manufacturing products in an environmentally responsible manner. NI recognizes that eliminating certain hazardous substances from our products is beneficial to the environment and to NI customers.

For additional environmental information, refer to the *Minimize Our Environmental Impact* web page at [ni.com/environment](#). This page contains the environmental regulations and directives with which NI complies, as well as other environmental information not included in this document.

## Waste Electrical and Electronic Equipment (WEEE)



**EU Customers** At the end of the product life cycle, all NI products must be disposed of according to local laws and regulations. For more information about how to recycle NI products in your region, visit [ni.com/environment/weee](https://ni.com/environment/weee).

## 电子信息产品污染控制管理办法（中国 RoHS）



**中国客户** National Instruments 符合中国电子信息产品中限制使用某些有害物质指令 (RoHS)。关于 National Instruments 中国 RoHS 合规性信息，请登录 [ni.com/environment/rohs\\_china](https://ni.com/environment/rohs_china)。(For information about China RoHS compliance, go to [ni.com/environment/rohs\\_china](https://ni.com/environment/rohs_china).)

Information is subject to change without notice. Refer to the *NI Trademarks and Logo Guidelines* at [ni.com/trademarks](http://ni.com/trademarks) for information on NI trademarks. Other product and company names mentioned herein are trademarks or trade names of their respective companies. For patents covering NI products/technology, refer to the appropriate location: **Help»Patents** in your software, the `patents.txt` file on your media, or the *National Instruments Patent Notice* at [ni.com/patents](http://ni.com/patents). You can find information about end-user license agreements (EULAs) and third-party legal notices in the `readme` file for your NI product. Refer to the *Export Compliance Information* at [ni.com/legal/export-compliance](http://ni.com/legal/export-compliance) for the NI global trade compliance policy and how to obtain relevant HTS codes, ECCNs, and other import/export data. NI MAKES NO EXPRESS OR IMPLIED WARRANTIES AS TO THE ACCURACY OF THE INFORMATION CONTAINED HEREIN AND SHALL NOT BE LIABLE FOR ANY ERRORS. U.S. Government Customers: The data contained in this manual was developed at private expense and is subject to the applicable limited rights and restricted data rights as set forth in FAR 52.227-14, DFAR 252.227-7014, and DFAR 252.227-7015.

© 2002—2018 National Instruments. All rights reserved.

373315H-01 May 31, 2018